

No .E-41/SDO/PWD(R&B)/PNSI/ 1655  
Government of Tripura  
Office of the Sub-Divisional Officer, PWD(R&B)  
Panisagar Sub-Division, Panisagar, North Tripura.

Dated 6<sup>th</sup> Dec, 2022

To  
The AHM, HO & DDO,  
Tilthai RC HS School,  
Dharmanagar, North Tripura.

Sub: - Submission of Building safety Certificate

Ref. letter No.F.1 (59) - HM/TRHS/DMN/ESTT/2022/267 Date the 2<sup>nd</sup> Dec, 2002.

Sir,

This is to bring to your kind notice that the above mentioned building is a G+1 Load Bearing structure with 254 mm thick Brick work on the periphery and 125 mm thick brick work on partition walls, wooden doors, frames of MS steel with Float glass glazing on windows, RCC roof slab which has been inaugurated during June, 2012. As per Visual inspection it has been found that the building is in good condition with mild requirement of plaster repairs. Overall it is certified the Building is safe for getting affiliation by the Central Board of Secondary Education, New Delhi.

Yours faithfully

ML  
6.12.22

(Er. Alok Das)  
Sub-Divisional Officer, PWD(R&B)  
Panisagar Sub-Divisi on